

DOCUMENT 00 91 01

ADDENDUM NO. 1

Dated May 14, 2024

1. GENERAL

This document includes requirements that clarify or supersede portions of the bid and/or contract requirements for the project. This Addendum is a Contract Document.

2. SUMMARY

The following changes, additions and deletions shall be made to the following document(s) as noted in **RED**; all other conditions shall remain the same.

Q&A

1. At the end of the run where all the Post & Beams are replaced, how is the 6" X 12" Beams attached to the building? Bolt or lag?

Answer: Bolt

2. Are there any special Inspections required for the Rebar, Epoxy, Dowels?

Answer: No

END OF DOCUMENT